



VITAL

Grenville Court, Britwell Road, Burnham, Slough SL1 8DF

📞 0345 111 7700 🌐 vitaldirect.co.uk


ENERGY PERFORMANCE CERTIFICATE

**Banbury Cross Inn
7 Butchers Row
Banbury
OX16 5JH**

14 March 2025

UK-wide services

- Energy Performance Certificates
- EPC Plus Upgrade reports
- Display Energy Certificates
- Asbestos Surveys
- Decarbonisation reports
- Heat Network regulations & ESOS
- FRA & GRA Assessments
- Air-conditioning Inspections



Energy performance certificate (EPC)

Banbury Cross Inn 7 Butchers Row BANBURY OX16 5JH	Energy rating	Valid until: 13 March 2035
	D	Certificate number: 5922-6135-4192-8097-9806


Property type	Restaurants and Cafes/Drinking Establishments/Takeaways
Total floor area	472 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

32 B

If typical of the existing stock

129 F

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	90.65
Primary energy use (kWh/m ² per year)	563

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0975-2219-6495-4902-1880\)](/energy-certificate/0975-2219-6495-4902-1880).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Robert Sims
Telephone	07966 468840
Email	robert.sims@hotmail.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID207470
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 March 2025
Date of certificate	14 March 2025

Energy performance certificate (EPC) recommendation report

Banbury Cross Inn
7 Butchers Row
BANBURY
OX16 5JH

Report number
0975-2219-6495-4902-1880

Valid until
13 March 2035

Energy rating and EPC

This property's energy rating is D.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Improve insulation on HWS storage.	Low
Consider replacing heating boiler plant with high efficiency type.	High
Add optimum start/stop to the heating system.	Medium
Consider replacing T8 lamps with retrofit T5 conversion kit.	Medium
The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.	High
Some windows have high U-values - consider installing secondary glazing.	High
Add weather compensation controls to heating system.	Medium
Some loft spaces are poorly insulated - install/improve insulation.	High
Add local time control to heating system.	Medium
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	Low

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	High
Consider replacing heating boiler plant with a condensing type.	High
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	High
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	High
Consider installing an air source heat pump.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Some floors are poorly insulated - introduce and/or improve insulation. Add insulation to the exposed surfaces of floors adjacent to underground, unheated spaces or exterior.	High
Roof is poorly insulated. Install or improve insulation of roof.	High

Recommendation	Potential impact on carbon emissions
Consider installing solar water heating.	Low
Consider installing PV.	Low

Property and report details

Report issued on	14 March 2025
Total useful floor area	472 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v6.1.e, SBEM, v6.1.e.0

Assessor's details

Assessor's name	Robert Sims
Telephone	07966 468840
Email	robert.sims@hotmail.co.uk
Employer's name	
Employer's address	
Assessor ID	QUID207470
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Quidos Limited
